



Model 8800 Communicating Thermostat System Installation Manual

READ AND SAVE THESE INSTRUCTIONS

COMMUNICATING THERMOSTAT SYSTEM INSTALLATION MANUAL

This manual will guide the installer through the installation, wiring and checkout of an Aprilaire® Model 8800 Communicating Thermostat System. For a complete command set with programming suggestions, see the programming manual (Part No. 10009414). Please visit www.aprilairepartners.com/docs/literature for this document.

TABLE OF CONTENTS

Collect the components needed	3
Disconnect power to all HVAC equipment and/or zone control panels	4
Run the required wires and mount the system components	5
Connect the control wires to the HVAC/zone system and thermostats	7
Connect the communication and power wires to the distribution panel and thermostat	8
Connect multiple distribution panels	9
Connect protocol adapter to the distribution panel and host computer or automation system	10
Check-out HVAC system operation	11
Set thermostat address and total number of thermostats	11
Setup computer for communication system checkout	12
Check-out communications to the thermostat network	15
Appendix 1 – Special considerations for installing the Model 8800 with the 8870 Series Communicating Thermostat	16
Appendix 2 – Sensor averaging	17

WARNING

- 1. 120 volts may cause serious injury from electrical shock. Disconnect electrical power to the HVAC system before starting installation. This system is a low-voltage system.**
- 2. Improper installation may cause serious injury from electrical shock. This system must be installed by a qualified contractor in accordance with NEC Standards and applicable local and state codes.**

COLLECT THE COMPONENTS NEEDED


TOOLS NEEDED

- Small flat head screwdriver for terminal screws (1/8" wide tip).
- Medium size flat/phillips head screwdriver for component mounting screws.
- Volt/ohm meter.
- Computer with available com port (RS-232) and terminal emulator such as HyperTerminal (for system checkout).
- Wire strippers.
- Small level (use to mount components level, required for appearance only).

WIRE NEEDED


- Multi-conductor thermostat cable (18–20 gauge).
- Category 5 communication wire (4 pair twisted cable).

SYSTEM COMPONENTS




Model 8800 Communicating Thermostat

The Model 8800 thermostat is an RS-485 communicating thermostat, configurable for single and multi-stage heat/cool or heat pump systems. It is also configurable as a whole home humidifier/dehumidifier control.




Model 8819 Distribution Panel

The distribution panel is a switch controlled communication bus that can be wired to eight Model 8800 thermostats. This allows thermostat communication to be turned on and off at one convenient location which simplifies installation and troubleshooting.



Model 8811 Protocol Adapter

The 8811 protocol adapter is used to convert an RS-485 communication signal to an RS-232 signal that is readable by a host computer's serial port.




Automation System Controller

RS-232 or RS-485 based automation system controller such as the Aprilaire System Controller.

MODEL 8081 AND 8082 SUPPORT MODULES (OPTIONAL)


Support modules can be added if you require additional temperature or humidity values. Support modules can also be used for sensor averaging in large areas.



Model 8081 Support Module

Provides two temperature values.

- One onboard or remote temperature sensor.
- One remote temperature sensor.



Model 8082 Support Module

Provides one temperature and one humidity value.

- One onboard humidity sensor.
- One onboard or remote temperature sensor.


⚠ WARNING

Use only the correct support module with each thermostat. Damage will occur if they are mixed.
8800s use only 8081 & 8082 support modules. 8870s use only 8061 & 8062 support modules.


MODEL 8051, 8052 AND 8053 REMOTE TEMPERATURE SENSORS (OPTIONAL)

These sensors can be used directly with the Model 8800 thermostat or with support modules.


Model 8051 Flush Mount Sensor



Model 8052 Outdoor Temperature Sensor



Model 8053 Wall Mount Sensor



FOR EASE OF INSTALLATION AND TROUBLESHOOTING DO THE FOLLOWING:

- Use Category-5 cable for all communication wiring.
- Check and recheck to ensure connection to the proper terminals before powering up the thermostats. Use wire color as a guide and be consistent.
- Use a Distribution Panel on all systems with more than one zone to simplify wiring and troubleshooting.

DISCONNECT POWER TO ALL HVAC EQUIPMENT AND/OR ZONE CONTROL PANELS

- If the thermostats are wired to a zone control panel, there is generally one set of input terminals supplying power to the thermostats and dampers. This must be disconnected.
- If the thermostats are wired directly to HVAC equipment, the power must be shut off at the equipment. This can generally be accomplished by turning off the disconnect switch located near the equipment. If an obvious disconnect switch is unavailable, you will need to turn the circuit off using the fuse or circuit breaker. Remove the fuse or shut down the circuit breaker serving the equipment.


CAUTION

Failure to disconnect power could result in damage to the HVAC equipment or thermostats. Leave power disconnected until all other electrical connections have been made and checked for accuracy.

RUN THE REQUIRED WIRES AND MOUNT THE SYSTEM COMPONENTS

1. Determine component locations.
2. Run and label wires. Use **FIGURE 1** for selecting wire type.
3. Mount components as specified in each product's installation instructions.

FIGURE 1 – Run Wire for System



Maximum Wiring Distances

From	To	Maximum Distance
Automation or Computer System	Protocol Adapter	3 ft. Cable Provided with Protocol Adapter
Protocol Adapter	Thermostat (this includes going through the Distribution Panel)	4000 ft. (cumulative)
Thermostat	Support Module	1000 ft. (cumulative)
Support Module	Temperature Sensor Option	300 ft.
Thermostat	Temperature Sensor Option	300 ft.

FIGURE 2 – Network Interconnection Worksheet


Fill Out and Leave with System Software Package

JOB TITLE: _____

JOB LOCATION: _____

DATE: _____


INSTALLING
CONTRACTOR: _____



LOCATION _____
ADDRESS _____


CAT-5
WIRE

DISTRIBUTION PANEL LOCATION / NAME




LOCATION _____
ADDRESS _____

CAT-5
WIRE




LOCATION _____
ADDRESS _____

CAT-5
WIRE




LOCATION _____
ADDRESS _____

CAT-5
WIRE




LOCATION _____
ADDRESS _____

CAT-5
WIRE



LOCATION _____
ADDRESS _____

CAT-5
WIRE




LOCATION _____
ADDRESS _____

CAT-5
WIRE

CAT-5
WIRE

TO DISTRIBUTION PANEL



LOCATION _____
ADDRESS _____

CAT-5
WIRE

Aprilaire®
DISTRIBUTION PANEL

CONNECT THE CONTROL WIRES TO THE HVAC/ZONE SYSTEM AND THERMOSTATS

A qualified HVAC technician should perform this step to ensure proper termination.

1. Make sure the HVAC system power is off.
2. The Thermostat Installation Instructions show wiring diagrams for several different HVAC equipment types. Use **FIGURES 3-5** as a reference only. Use color coding where possible.

Refer to the thermostat installation manual for check-out procedure and other wiring details

DO NOT TURN ON THE HVAC SYSTEM POWER YET!

FIGURE 3 – Conventional Heat/Cool

**SINGLE TRANSFORMER
(USE JUMPER WIRE)**




FIGURE 4 – Heat Pump

**SINGLE TRANSFORMER
(USE JUMPER WIRE)**

NOTE: "O" is active in cooling and "B" is active in heating.






FIGURE 5 – Humidistat

DRY CONTACT




POWERED CONTACT



CONNECT THE COMMUNICATION AND POWER WIRES TO THE DISTRIBUTION PANEL AND THERMOSTAT

1. **MAKE SURE THAT ALL SWITCHES ON THE DISTRIBUTION PANEL ARE OFF!**
2. Connect the communication wires. **FIGURE 6** shows how each thermostat is to be wired to the distribution panel.
 - Use the wire colors shown in **FIGURE 6** to help ensure proper, consistent connections.
3. Use a Model 8029 24VAC transformer or equivalent to power each distribution panel.


FIGURE 6 – System Communication Wiring



CONNECT MULTIPLE DISTRIBUTION PANELS

1. **MAKE SURE THAT ALL SWITCHES ON THE DISTRIBUTION PANELS ARE OFF!**
2. If more than one Distribution Panel is used in the thermostat network, the communication lines must be daisy-chained together.
 - Use the wire colors shown in **FIGURE 7** to help ensure proper, consistent connections.
3. Power each distribution panel with a separate Model 8029 24VAC transformer or equivalent 40VA 24VAC transformer.

FIGURE 7 – Multiple Distribution Panels



CONNECT PROTOCOL ADAPTER TO THE DISTRIBUTION PANEL AND HOST COMPUTER OR AUTOMATION SYSTEM

1. MAKE SURE THAT ALL SWITCHES ON THE DISTRIBUTION PANEL ARE OFF!


2. Use Category-5 wire to connect the main communication terminals on the Distribution Panel to the "Breakout Adapter" of the protocol adapter (see **FIGURE 8**).

3. Connect the RS-232 cable from the protocol adapter to the computer or automation system. A 3 ft. RS-232 cable is provided.

Some computers use 25-pin connectors on serial ports, which requires a DB25 connector. A DB9 connector fits a 9-pin port. DB9 to DB25 transitions are available at most computer retail stores.

4. Power up the Protocol Adapter with the plug-in transformer provided. The "Power" LED on the Protocol Adapter should light up when power is applied.

FIGURE 8 – Protocol Adapter Wiring



CHECK-OUT HVAC SYSTEM OPERATION

Use the thermostat to verify that the equipment is being controlled. A checkout procedure is supplied in the installation instructions with the thermostat. This procedure will verify only that the thermostat operates the equipment. Communication system checkout will be performed next.

SET THERMOSTAT ADDRESS AND TOTAL NUMBER OF THERMOSTATS

IMPORTANT!

THESE STEPS MUST BE DONE AT EACH THERMOSTAT FOR COMMUNICATION TO WORK PROPERLY.

1. Enter the thermostat's Installer Setup Menu.

Press [MODE] to set system to OFF.

Press [MENU] to enter main menu.

Press and hold [SETUP] for seven seconds, **[INSTALL SETUP]** appears.

Press [INSTALL SETUP] to enter installer setup menu.

Press [NEXT] or **[BACK]** to page through the settings.

2. Select System Setting **00 NETWORK ADDRESS**.

Press up or **down** to adjust the setting.

- Numbering should start at **1** and continue sequentially (64 maximum).
- No two thermostats should have the same address.

3. Select System Setting **01 NUMBER OF NODES** and set the total number of thermostats on the network.

Press up or **down** to adjust the setting.


- This number must be set the same on all thermostats.

4. (Optional depending on automation equipment) Select System Setting **02 BAUD RATE** and set the communication baud rate. Default is 9600.

5. **Press [DONE]** to save and exit, or **[CANCEL]** to exit without saving.

The thermostat will discard changes and exit if nothing is pressed within 60 seconds.

To reset the installer settings to the default, reset the thermostat by pressing the **[RESET]** button inside the battery cover.



SETUP COMPUTER FOR COMMUNICATION SYSTEM CHECKOUT


REQUIREMENT: HyperTerminal software and a PC with a serial port or usb to serial port adapter.

1. Connect the Protocol Adapter RS-232 output to a computer with Windows '95, '98, Windows 2000, Windows NT, or XP.

Note: Newer Windows systems may not include HyperTerminal.

2. From the **Start** menu, select **PROGRAMS** ➤ **ACCESSORIES** ➤ **COMMUNICATION** ➤ **HYPERTERMINAL**. HyperTerminal is a terminal emulator program provided with Windows that will be used to test the communication system.
3. Double click the **Hypertm** icon. You will then be asked to name the new connection and select an icon. Type in any name you want (the shorter the better) and select the "atom-like" symbol at the end of the Icon list (see **FIGURE 10**). Then click **OK**.

FIGURE 10 – New Connection



4. This will bring up a **Connect to** dialog box. From the pull down next to "Connect using:", select the Com port to which the Protocol Adapter is connected (see **FIGURE 11**). Start with Com port 1 (or the next lowest available number) if you are unsure which one to use. Click **OK**.

FIGURE 11 – Select Com Port



5. A **COM1 Properties** dialog box should appear. Use the pull-down menus or type in the following for each selection (see **FIGURE 12**):

Bits per second: 9600 (or 19200 if thermostats are configured for this baud rate)

Data bits: 8


Parity: None

Stop bits: 1

Flow control: none


Click **OK**.

FIGURE 12 – Connection Properties



6. From the **File** pull-down menu, select **Properties**. This will bring up a **Properties** dialog box.
7. Select the **Settings** tab. Make the following selections (see **FIGURE 13**):
 - Terminal keys
 - Ctrl+H
 - Emulation: Auto Detect
 - Telnet terminal: ANSI
 - Backscroll buffer lines: 500

FIGURE 13 – Terminal Settings




8. Then select the **ASCII Setup** button. This will bring up an ASCII Setup dialog box. Make the following selections (see **FIGURE 14**):

- ✓ Echo typed characters locally
- ✓ Append line feeds to incoming line ends
- ✓ Wrap lines that exceed terminal width

NOTE:

IF USING AN EXISTING HYPERTERMINAL CONNECTION YOU MAY NEED TO UNCHECK THE "SEND LINE FEEDS..." BOX.

FIGURE 14 – ASCII Setup



9. Click **OK** to put away both dialog boxes.
10. Verify that you have a connection between the computer and the Protocol Adapter. Have the Protocol Adapter within eyesight of the computer keyboard. Type any character and confirm that the "RXD" LEDs on the Protocol Adapter flash as you type (see **FIGURE 8** on page 10). The LEDs flash very quickly.
11. Press Enter to clear the command line.

Note: On Windows '98 computers, HyperTerminal does not echo typed characters (doesn't show them on the screen as you type) locally. Do not be concerned. This can be a little confusing, but does not affect the checkout of the thermostat communication system.

- **If you were unable to verify a connection**, specify a different com port. Go to the **File** pull down menu, and select **Properties**. Change the "**Connect using:**" setting to a different port by using the pull down menu options. Start typing and look for the Protocol Adapter "RXD" or "TXD" LEDs to flash. Repeat until you have successfully verified connection between the computer and communication system, or until you run out of com ports to choose from in the "**Connect using:**" pull down. If there is still no communication you are going to have to consult a computer professional.

CHECK-OUT COMMUNICATIONS TO THE THERMOSTAT NETWORK

This section confirms communications to each thermostat and each thermostats network address.

1. At the distribution panel turn on the communication switches A and B for the thermostat with address#1 (see **FIGURE 15**).
2. At the Hyperterminal program type: **SN ID?** and press **Enter**.

You should see response:

SN1 MODEL# 8800 VER: x.xxx - RPC 2011 (x.xxx represents the current firmware version number)

- If the response is not exactly as shown, there is a communication signal problem. The most likely sources are a loose terminal connection, incorrect wiring, incorrect wire type, damaged wire, electrical interference or incorrect power supply.

3. Now back at the distribution panel turn on the communication switches A and B for the thermostat with address#2.
4. At the Hyperterminal program type: **SN ID?** and press **Enter**.


You should see response from both thermostats:

SN1 MODEL# 8800 VER: x.xxx - RPC 2011

SN2 MODEL# 8800 VER: x.xxx - RPC 2011

5. Repeat this process adding one thermostat each time to verify communications to all thermostats. Each time you turn on the communication switches and send SN ID? command to a new thermostat, a new "SN" number should respond.
6. Once you have successfully completed this procedure you have verified that proper communication exists between the computer and all of the thermostats. To test out all of the functions of the thermostat, use the software or automation package being installed with this system.

FIGURE 15 – Com Switches




APPENDIX 1 – SPECIAL CONSIDERATIONS FOR INSTALLING THE MODEL 8800 WITH THE 8870 COMMUNICATING THERMOSTAT

⚠ WARNING

WHEN REPLACING AN 8870 THERMOSTAT WITH THE MODEL 8800 THERMOSTAT THESE ADDITIONAL STEPS ARE REQUIRED IN ORDER FOR PROPER OPERATION.

1. The 8800 Thermostat cannot be powered from an 8818 Distribution Panel. The 8800 Thermostat must be powered from a separate 24VAC transformer.
2. The Model 8800 thermostat must be set to non-programmable mode to be used in a 8870/8818 system.
3. Replace any 8061 TT Support Modules connected to the thermostat with 8081 TT Support Modules, but in cases where a single flush mount and/or outdoor sensor is used they can be directly connected to the new 8800 Thermostat and the Support Module can be eliminated.
4. Replace any 8062 TrH Support Modules connected to the thermostat with 8082 TrH Support Modules.


FIGURE 16



APPENDIX 2 – SENSOR AVERAGING

This is an option for sensor averaging that does not require support modules. This option can only be used with a specific number of sensors (4 or 9).


FIGURE 17




FOUR SENSOR TEMPERATURE AVERAGING – WIRING

WIRING SHOWN USING MODEL 8051 FLUSH MOUNT SENSORS.
SAME WIRING FOR MODEL 8053 SURFACE MOUNT SENSORS.

90-1585




FOUR SENSOR TEMPERATURE AVERAGING – SCHEMATIC



NINE SENSOR TEMPERATURE AVERAGING – WIRING

WIRING SHOWN USING MODEL 8051 FLUSH MOUNT SENSORS.
SAME WIRING FOR MODEL 8053 SURFACE MOUNT SENSORS.

90-1584



NINE SENSOR TEMPERATURE AVERAGING – SCHEMATIC



P.O. Box 1467 • Madison, WI 53701-1467 • Phone: 800/334-6011 • Fax: 608/257-4357 • www.aprilairepartners.com